


Collier County Fire Prevention and Protection Code POLICY AND PROCEDURE MANUAL



ARTICLE NUMBER: FDC 09-2

EFFECTIVE DATE: 1/1/2009

SUBJECT: Fire Department Connections Serving High Rise Buildings

OBJECTIVE Clarify the Fire Department Connections placement requirements for High rise buildings

BACKGROUND: NFPA 24 and 14 require AHJ approval of the number and placement of Fire appliances. Current fire fighting operational procedures used by the Fire Districts in Collier County are based upon the following placement requirements.

POLICY/PROCEDURE: New high-rise buildings shall be equipped with two fire department connections. One connection shall be located at the building and one shall be located within 15 feet of a fire hydrant. Either fire department connection shall be capable of operating independently of the other. The second fire department connection required at the building shall not be required to be required to be located within 50 of a fire hydrant.

CODE REFERENCES: NFPA 24-7.2.1 2002 Edition, NFPA 14 – 5.1.2

ATTACHMENTS: None.

DISTRIBUTION: Big Corkscrew Island Fire District; East Naples Fire District; Golden Gate Fire District; Immokalee Fire District; Isle of Capri Fire District; North Naples Fire District; Ochopee Fire District; City of Marco Island Fire Department; Building Director, Collier County Community Development; Chief Inspectors, Collier County Community Development; Collier County Community Development Records; Collier Building Industry Association (CBIA); Subscribers