


# Collier County Fire Prevention and Protection Code POLICY AND PROCEDURE MANUAL



**ARTICLE NUMBER:** FSK 02-2

**EFFECTIVE DATE:** May 14, 2002

**SUBJECT:** Maximum Number of Buildings utilizing one Fire Pump

**OBJECTIVE:** To prohibit more than three buildings from being placed on one Fire Pump

**BACKGROUND:**

Fire Department personnel provide fire watches when building safety systems are out of service. The fire departments do not have the manpower to handle multiple firewatches for one fire pump system servicing more than three buildings. Therefore the number of buildings serviced by one fire pump shall not exceed three.

**POLICY/PROCEDURE:**

Buildings within developments and under the same ownership may utilize one fire pump for up to three buildings in that development. If ownership for the buildings change to multiple owners, separate fire pumps shall be required. Multiple ownership of residential properties under a condominium association shall not be subject to this rule.

**CODE REFERENCES:**

None

**ATTACHMENTS:**

None.

**DISTRIBUTION:** Big Corkscrew Island Fire District; East Naples Fire District; Golden Gate Fire District; Immokalee Fire District; Isle of Capri Fire District; North Naples Fire District; Ochopee Fire District; City of Marco Island Fire Department; Building Director, Collier County Community Development; Chief Inspectors, Collier County Community Development; Collier County Community Development Records; Collier Building Industry Association (CBIA); Subscribers