


# Collier County Fire Prevention and Protection Code POLICY AND PROCEDURE MANUAL



**ARTICLE NUMBER:** FSK 02-3

**EFFECTIVE DATE:** August 13, 2002

**SUBJECT:** Fire Pump Enclosures Serving Multiple Buildings

**OBJECTIVE:** To provide clarification of local requirements for a separate building for fire pumps used for multiple buildings

**BACKGROUND:**

Damage to a building housing the fire pump for multiple buildings may mean that the pump will be out of service for several buildings instead of just the one.

**POLICY/PROCEDURE:**

When a fire pump is used for multiple buildings, the fire pump shall be housed in a building separate from the buildings it services. The fire pump enclosure shall be protected with an automatic supervised sprinkler system.

**CODE REFERENCES:**

None

**ATTACHMENTS:**

None.

**DISTRIBUTION:** Big Corkscrew Island Fire District; East Naples Fire District; Golden Gate Fire District; Immokalee Fire District; Isle of Capri Fire District; North Naples Fire District; Ochopee Fire District; City of Marco Island Fire Department; Building Director, Collier County Community Development; Chief Inspectors, Collier County Community Development; Collier County Community Development Records; Collier Building Industry Association (CBIA); Subscribers