




Collier County Fire Prevention and Protection Code POLICY AND PROCEDURE MANUAL



ARTICLE NUMBER: FSK 02-6

EFFECTIVE DATE: May 14, 2002

SUBJECT: Fire Department Connections

OBJECTIVE: To standardize the FDC size at all locations.

BACKGROUND:

The codes related to NFPA 13, 13R and 13D allow 2 ½ inch and 1 ½ inch FDCs. However, standardization to one size (2 ½ inch) will provide uniform response of firefighting units and make the process of hooking up to the FDC consistent and more efficient.

POLICY/PROCEDURE:

All Fire Department Connections shall be 2 ½ inch NST male thread. FDCs shall be installed and maintained with protective caps.

CODE REFERENCES:

None

ATTACHMENTS:

None.

DISTRIBUTION: Big Corkscrew Island Fire District; East Naples Fire District; Golden Gate Fire District; Immokalee Fire District; Isle of Capri Fire District; North Naples Fire District; Ochopee Fire District; City of Marco Island Fire Department; Building Director, Collier County Community Development; Chief Inspectors, Collier County Community Development; Collier County Community Development Records; Collier Building Industry Association (CBIA); Subscribers