




Collier County Fire Prevention and Protection Code POLICY AND PROCEDURE MANUAL



ARTICLE NUMBER: FSK 02-7

EFFECTIVE DATE: August 13, 2002

SUBJECT: Sprinkler Protection of Fire Pump Rooms, Buildings and/or Enclosures

OBJECTIVE: To increase the protection required for fire pumps in rooms of buildings being served, separate buildings and/or enclosures.

BACKGROUND:

Collier County Fire Marshals have determined that buildings or enclosures utilized for fire pumps separated from main buildings need to be protected by an approved automatic supervised fire sprinkler system. While NFPA 20 5.12.1.3 only requires sprinkler protection in pump houses containing diesel engines and fuel, protection of these essential devices, independent of the type of pump, is desired and may prevent extended fire watches in the event of damage to the structure and/or equipment.

POLICY/PROCEDURE:

All fire pump rooms, buildings, enclosures, and the like shall be protected by an approved automatic supervised fire sprinkler system whether attached to the building being served or not in accordance with NFPA 13 29.1.8 (.25 gpm/sq. ft).

CODE REFERENCES:

NFPA 20 2003 5.12.1.3
NFPA 13 29.1.8

ATTACHMENTS:

None

DISTRIBUTION: Big Corkscrew Island Fire District; East Naples Fire District; Golden Gate Fire District; Immokalee Fire District; Isle of Capri Fire District; North Naples Fire District; Ochopee Fire District; City of Marco Island Fire Department; Building Director, Collier County Community Development; Chief Inspectors, Collier County Community Development; Collier County Community Development Records; Collier Building Industry Association (CBIA); Subscribers

This policy updated April 2009