


Collier County Fire Prevention and Protection Code POLICY AND PROCEDURE MANUAL



ARTICLE NUMBER: FSK 02-8

EFFECTIVE DATE: August 13, 2002

SUBJECT: Fire Pumps Serving Multiple Buildings

OBJECTIVE: To allow two pumps to serve multiple buildings thereby reducing the final cost for protection

BACKGROUND:

Collier County Fire Marshals have determined that one fire pump system may only service a total of three buildings without backup. In order to increase the number of buildings served by pumps in larger projects (i.e.: more than six buildings), it has been determined that two pumps can be utilized together. The failure of one pump will not affect the operation of the sprinkler or standpipe system of any single building in the project thus providing better protection than requiring one pump for every three buildings.

POLICY/PROCEDURE:

In multiple building projects, two fire pump systems tied together so that the failure of one will not affect the other for the protection of all buildings, shall allow an exception to Policy and Procedure Document FSK02-03 provided both fire pump systems have the capacity to handle the water and pressure requirements for the largest building in the project.

CODE REFERENCES:

None

ATTACHMENTS:

None

DISTRIBUTION: Big Corkscrew Island Fire District; East Naples Fire District; Golden Gate Fire District; Immokalee Fire District; Isle of Capri Fire District; North Naples Fire District; Ochopee Fire District; City of Marco Island Fire Department; Building Director, Collier County Community Development; Chief Inspectors, Collier County Community Development; Collier County Community Development Records; Collier Building Industry Association (CBIA); Subscribers