



# Collier County Fire Prevention and Protection Code POLICY AND PROCEDURE MANUAL



**ARTICLE NUMBER:** HYD 09-3

**EFFECTIVE DATE:** 1/1/2009

**SUBJECT:** Fire Hydrant Placement - General

**OBJECTIVE:** To provide Minimum Fire Hydrants Spacing Requirements

**BACKGROUND:** The 2006 edition of NFPA 1 Sections 13.5, 18.1 and 18.3 as well as the 2002 edition of NFPA 24 require fire hydrants to be installed as approved by the AHJ.

**POLICY/PROCEDURE:**

Maximum distance between fire hydrants shall be five hundred (500) feet in exclusive one and two family areas with buildings not exceeding 5000 sq ft, and three hundred (300) feet in all other areas.

**CODE REFERENCES:** NFPA 1, 2006 Edition, NFPA 24, 2002 Edition

**ATTACHMENTS:** None.

**DISTRIBUTION:** Big Corkscrew Island Fire District; East Naples Fire District; Golden Gate Fire District; Immokalee Fire District; Isle of Capri Fire District; North Naples Fire District; Ochopee Fire District; City of Marco Island Fire Department; Building Director, Collier County Community Development; Chief Inspectors, Collier County Community Development; Collier County Community Development Records; Collier Building Industry Association (CBIA); Subscribers