



Collier County Fire Prevention and Protection Code

POLICY AND PROCEDURE MANUAL



ARTICLE NUMBER: SDP 09-1

EFFECTIVE DATE: 1/1/2009

SUBJECT: Manual Wet Standpipe Systems in Buildings classified as three or four stories in height

OBJECTIVE: Reduce the possibility of a standpipe system failure due to corrosion within the piping.

DEFINITION: Manual-Wet Standpipe System: Wet standpipe system connected to a small water supply for the purpose of maintaining water within the system, but does not have the water supply capable of delivering the system demand attached to the system.

BACKGROUND: There have been several older dry standpipe systems that have failed during periodic hydrostatic testing.

POLICY/PROCEDURE:

Manual Wet Standpipe Systems in Buildings three or four stories above grade shall have manual wet standpipe systems installed in accordance with NFPA 14.

CODE REFERENCES: NFPA 1 13.2.2.2; NFPA 14 -5.1.2 2003 Edition

ATTACHMENTS: None.

DISTRIBUTION: Big Corkscrew Island Fire District; East Naples Fire District; Golden Gate Fire District; Immokalee Fire District; Isle of Capri Fire District; North Naples Fire District; Ochopee Fire District; City of Marco Island Fire Department; Building Director, Collier County Community Development; Chief Inspectors, Collier County Community Development; Collier County Community Development Records; Collier Building Industry Association (CBIA); Subscribers