


# Collier County Fire Prevention and Protection Code

## POLICY AND PROCEDURE MANUAL



**ARTICLE NUMBER:** SDP 09-3

**EFFECTIVE DATE:** 1/1/2009

**SUBJECT:** Standpipe Systems in high-rise buildings.

**OBJECTIVE:** To clarify the requirements for standpipe systems located in high-rise buildings

**BACKGROUND:** This policy clarifies the requirements of standpipe systems in high-rise buildings.

**POLICY/PROCEDURE:**

Any building classified as a high-rise building as defined by the Florida Fire Prevention Code, 2007 edition shall have an automatic wet standpipe system in accordance with NFPA 14 capable of supplying the required gallons per minute with a residual pressure of 100 psi at the uppermost hose connection.

**CODE REFERENCES:** NFPA 1-13.2.2.2: NFPA 14 - 5.1.2 2003 Edition

**ATTACHMENTS:** None.

**DISTRIBUTION:** Big Corkscrew Island Fire District; East Naples Fire District; Golden Gate Fire District; Immokalee Fire District; Isle of Capri Fire District; North Naples Fire District; Ochopee Fire District; City of Marco Island Fire Department; Building Director, Collier County Community Development; Chief Inspectors, Collier County Community Development; Collier County Community Development Records; Collier Building Industry Association (CBIA); Subscribers