


Collier County Fire Prevention and Protection Code POLICY AND PROCEDURE MANUAL



ARTICLE NUMBER: HYD 09 - 4

EFFECTIVE DATE: 1/1/2009
(Amended 05/31/2011)

SUBJECT: Structures that are within a 1000' of a Water Main

OBJECTIVE: To clarify when new construction of all Commercial projects and new single family subdivisions are required to connect to an existing central water supply.

BACKGROUND: NFPA 1 (2006 Florida-Specific Edition), section 18.3.1 allows the A.H.J. to determine the minimum distance to an approved water supply system to which the structures listed above must connect in order to supply the required fire flow for fire protection of the structure.

POLICY/PROCEDURE: All commercial projects and new single family subdivisions that are located within a 1000' of an approved water supply system need to be connected to that approved water supply system. NOTE: the distance is measured along the existing or proposed travel path to the structure.

CODE REFERENCES: NFPA 1 (2006 Florida-Specific Edition), section 18.3.1; NFPA 24 2002 Edition

ATTACHMENTS: None.

DISTRIBUTION: Big Corkscrew Island Fire District; East Naples Fire District; Golden Gate Fire District; Immokalee Fire District; Isle of Capri Fire District; North Naples Fire District; Ochopee Fire District; City of Marco Island Fire Department; Building Director, Collier County Community Development; Chief Inspectors, Collier County Community Development; Collier County Community Development Records; Collier Building Industry Association (CBIA); Subscribers